

**GOVERNMENT OF ANDHRA PRADESH  
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT**

From:  
Sri S.Sreedhar, M.A.,  
Asst. District Fire Officer,  
Anantapuramu.

To:  
The Secretary,  
Board of Intermediate Education.  
A.P. Vijayawada.

**Rc.No.2499/B2/2016, Dated:30-11-2016.**

Sub: Andhra Pradesh Disaster Response & Fire Services Department – Southern Region – Anantapur District – Issue of **Annual Fire Safety Certificate** to the Existing Educational Building of **LRG Naidu Junior College, S.Y.No.210-2A, At Kirikera, Hindupur, Anantapuramu District** -Regarding.

- Ref: 1. Section 13(2) of Andhra Pradesh Fire Services Act, 1999 and Rule 15(2) of A.P. Fire and Emergency Operations and Levy of Fee Rules, 2006.  
2. Chief Office instructions Memo Rc.No. of 2305/B2/2007, Dated 28-02-2007 and 12-09-2008.  
3. Letter from the Correspondent of **LRG Naidu Junior College, S.Y.No.210-2A, At Kirikera, Hindupur, Anantapuramu District** through Mee Seva,12CCHD000155571, Hindupur, Anantapuramu District, Dated:06 -09-2016.  
4. Renewal NOC Rc.No.2635/B2/2014, Dt, 20-08-2014 of the Assistant District Fire Officer, Anantapuramu & Rc.No.97/SFO/HDP/2015, Dated:21-08-2015 of the Station Fire Officer, Hindupur, Anantapuramu District.  
5. Circular Memorandum Rc.No.2305/B2/2007, Dated 02-04-2016 of the Director General State Disaster Response and Fire Services, Andhra Pradesh, Hyderabad.

--:--

In obedience to the instructions issued by Director General of Fire Services, Andhra Pradesh, Hyderabad vide reference 2<sup>nd</sup> cited, the Owner representative has reported that he has obtained No Objection certificate for occupancy for educational building from this department in reference 4<sup>th</sup> cited and requested to issue the Annual Fire Safety Certificate in terms of reference 3<sup>rd</sup> cited for the **LRG Naidu Junior College, S.Y.No.210-2A, At Kirikera, Hindupur, Anantapuramu District**.

2. Vide reference 5<sup>th</sup> cited, I have inspected the above building on 18-11-2016 and issue of Annual Fire Safety Certificate for the above Educational Building.

3). i) Particulars of the Educational Building:

a)	Address of the Building	<b>LRG Naidu Junior College, S.Y.No.210-2A, At Kirikera, Hindupur, Anantapuramu District.</b>
b)	Area of plot / Height of the building.	2.12 Acrs/ 8.30 Mtrs
c)	No of blocks / floors	01/Ground + 1 <sup>st</sup> Floor.

ii). **Open Spaces**

Side	Open Space to be provided as per NBC	Open Space provided	Deficit
North	6.00 Mts.	77.00 Mtrs.	Nil
East	6.00 Mts.	06.00 Mtrs.	Nil
South	6.00 Mts.	14.80 Mtrs.	Nil
West	6.00 Mts.	49.80 Mtrs.	Nil

iii. **Floor wise particulars:**

Sl. No.	Floor	Built-up Area in Sq. Mts.	Occupancy	Occupant load
1	Ground	2410.45	Educational	602
2	First	2410.45	Educational	200
	Total:	<b>4820.90</b>	--	<b>802</b>



::2::

Means of Escape (a):

Sl.No.	No. of Staircases	Width in Meters	Total Width
1.	Internal - 02No.	2.40+1.80 Mtrs	04.20 Mtrs.
	Total: -02 Nos.	04.20 Mtrs.	04.20 Mtrs.

b)

Highest No. of Students in a Floor	Width of Staircases required (No. of Students divided by 50=-----mts.	Aggregate Width of Staircases provided	Deficit
200	1200/50= 4.00 Mtrs.	4.20 Mtrs.	Nil

v) Fire Safety Measures:

Sl. No.	Fire Safety Measures	Required as per Table 23 of NBC of India 2005.	Provided	Deficiency
1.	Fire Extinguishers	32 No's	32 No's	Nil
2.	Hose Reel	32 Nos.	32 Nos.	Nil

The Management has remitted fire precaution fee 1) for Rs.24105/- Vide Challan No.12688, dt.03-09-2016 at Sub. Treasury, Hindupur.

4. The Fire Safety systems were tested by me, during the inspection and performance found satisfactory. Hence, it is issued **Annual Fire Safety Certificate** to the existing Educational Building **LRG Naidu Junior College, S.Y.No.210-2A, At Kirikera, Hindupur, Anantapuramu District**, subject to the following conditions.

i.	All the Fire Protection arrangements shall be maintained in good repair as seen during inspection.
ii.	All the escape / exit routes shall not be kept locked / blocked or encroached.
iii.	All the occupants must know the correct method of operation of the fire fighting system installed.
iv.	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.
V	All students / staff members of the institution shall be trained to operate the fire safety equipments during emergency.
vi.	Addition / alteration, if any in the building may be obtained with prior permission from this department.
vii.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in 3very 6 months.

5) *This Annual Fire Safety Certificate is valid for a period up to 19-08-2017 and the management may apply for Annual Fire Safety Certificate before 2 months and strictly applicable to the buildings show in attested plans with given occupant load only.*

Yours faithfully,

Asst. District Fire Officer,  
Anantapuramu,

Copy to the **LRG Naidu Junior College, S.Y.No.210-2A, At Kirikera, Hindupur, Anantapuramu District.**

Copy to the Station Fire Officer, Hindupur Fire Station.

Copy to the Regional Inspecting Officer, Anantapuramu.

Copy Submitted to the District Fire Officer, Anantapuramu for favour of kind information